

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7300-1076:116 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Kidde-Fenwal Inc., 400 Main St., Ashland MA 01721
Contact: Terrill Garland (508) 881-2000 *Fax (508) 881-1773

DESIGN: Models 2-WIRE, 2WRLT, 2WRB, 4WRB, 4SB, 6SB smoke detector bases and Models MA-001 and MA-002 smoke detector adapters. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 10.2 - 36.8 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Models 2-WIRE, 2WRLT, 2WRB, 4WRB are listed as a smoke detector base and Model MA-001 is listed as a smoke detector adapter for use with Models CPD-7051 (CSFM Listing No. 7271-1076:115), PSD-7155 or PSD-7156 (CSFM Listing No. 7272-1076:117) and separately listed compatible fire alarm control units. Models 2WRLT, 2WRB, 4WRB, 4SB and 6SB are also suitable for duct applications when used with Model RCM500 remote test/LED. Models 2WRB and 4WRB are suitable for releasing device service.

Models 4SB, 6SB are listed as smoke detector base and Model MA-002 is listed as a smoke detector adapter for use with listee's separately listed Model Fenwalnet 1000 (CSFM Listing No. 7165-1076:114), Fenwalnet 2000 (CSFM Listing No. 7165-1076:141), Fenwalnet 4000 (CSFM Listing No. 7165-1076:111) or Pegasys (CSFM Listing No. 7165-1076:146) fire alarm control units.

*Rev. 06-21-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 21, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager